## **EYS 25% \* Fill Vertical Sealing Fittings for Close Turning Radius**


## Explosionproof, Dust-Ignitionproof, Raintight

UNILETS™ for Use with Threaded Rigid Metal Conduit and IMC.

## NEC/CEC:

Class I, Division 1 and 2, Groups A◇, B, C, D Class II, Division 1 and 2, Groups E, F, G Class III

		Trade Size		Millimeters (Inches)	Kwiko <sup>™</sup> A Cement Required	Catalog Number	
		(Inches)	A (Length)	B (Width)	Turning Radius ①	Grams (Ounces)	Grayloy™–lron
EYS Vertical Se	ealing Fittings (2	25% fill)					
30		Female					
		1/2	83.3 (3.28)	31.7 (1.25)	41.4 (1.63)	28.4 (1.00)	EYS-1 $^{\diamond}$
		3/4	93.7 (3.69)	38.1 (1.50)	48.5 (1.91)	56.8 (2.00)	EYS-2 $^{\diamond}$
		1	109.4 (4.31)	44.4 (1.75)	60.4 (2.38)	85.1 (3.00)	EYS-3 $^{\diamond}$
		Male/Female (Removable Male Nipple)					
		1/2	83.3 (3.28)	31.7 (1.25)	41.4 (1.63)	28.4 (1.00)	EYS-16 <sup>◊</sup>
		3/4	93.7 (3.69)	38.1 (1.50)	48.5 (1.91)	56.8 (2.00)	EYS-26 <sup>◊</sup>
Female	Male	1	109.4 (4.31)	44.4 (1.75)	60.4 (2.38)	85.1 (3.00)	EYS-36 <sup>◊</sup>



\* Per NEC 501.15(C)(6), seals in Class I, Division 1 and 2 must be limited to conductor fill of 25% of cross sectional area of a rigid metal conduit of the same trade size unless approved for higher percentage fill. See 40% fill sealing fittings. ① Turning radius with cover or plug removed.

♦ Indicates items in the shaded area which are UL Listed for Class I, Groups A, B, C, D; Class II, Groups E, F, G; and Class III.