



UL LISTED, cUL CERTIFIED.
 CLASS I DIVISION 2, GROUPS A, B, C, D.
 CLASS II DIVISION 2, GROUP F, G.
 CLASS III. ENCLOSURE TYPE 4X
 CLASS I, ZONE 2, GROUP IIC T6

I & M SHEET IMP117.

174	8 TO 200	0.6 TO 13.8
173	4 TO 100	0.3 TO 6.9
172	2 TO 50	0.1 TO 3.4
171	1 TO 20	68.9 TO 1379 mbar
MODEL NO.	psi	bar
	ADJUSTABLE RANGE	
	LOW END OF RANGE ON FALL	
	HIGH END OF RANGE ON RISE	

SYM	DESCRIPTION	DATE	DVN	APPD
P	CHANGED kPa TO bar. ECN#E0047	10-23-02	S.R.	H.N.
N	REMOVED MODEL 175. ECN# C9107.	4/2/01	PLW	L.K.
M	REVISED kPa ADJ. RANGES. ADDED MODEL 175. ECN#C8460	1-20-00	S.R.	L.K.
L	REVISED VIEW OF TERMINAL BLOCK & SPECS.. ECN#C8438	11-22-99	S.R.	V.P.D.
K	DELETED MODELS 471-474 DC#25636	5/7/99	AB	AB
J	CERTIFICATION WAS CSA. REQUIREMENT NOTE WAS NEMA 4X, 7, 9. ECN#C7775	12-3-98	P.V.	S.F.
H	REDRAWN. ADDED 1" (25.4mm) & 3/16 (7.94mm) DIMENSIONS. ECN#C684B	10-31-97	P.W.	A.M.

ORIGINAL DATE	2-19-91
DRWN	PETER WEILER
CHKD	PETER WEILER
APPD	G. YUSKAUSKAS
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	

TITLE	H117
SCALE	HALF

DF001D

UNITED ELECTRIC CONTROLS COMPANY
 WATERTOWN * MASSACHUSETTS

DWG NO
 A-12836

REVISIONS

DO NOT SCALE THIS DRAWING