



UL LISTED, cUL CERTIFIED.  
 CLASS I DIVISION 2, GROUPS A, B, C, D.  
 CLASS II DIVISION 2, GROUP F, G.  
 CLASS III. ENCLOSURE TYPE 4X  
 CLASS I, ZONE 2, GROUP IIC T6

I & M SHEET IMP117.

194	494	80 TO 1700	5.5 TO 117.2
193	493	20 TO 500	1.4 TO 34.5
192	492	15 TO 300	1.0 TO 20.7
191	491	10 TO 100	0.7 TO 6.9
190	490	5 TO 30	0.3 TO 2.1
MODEL NO.	psi	bar	
	ADJUSTABLE RANGE		
	LOW END OF RANGE ON FALL		
	HIGH END OF RANGE ON RISE		

COVER REMOVED IN FRONT VIEW

ORIGINAL DATE 3-3-87					TITLE H117		DF001D	
DRAWN R. LEPAGE					CHECKED A.J.FLECCA		UNITED ELECTRIC CONTROLS COMPANY WATERTOWN * MASSACHUSETTS	
APPD A. MINASSIAN					UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES			
AL CHANGED kPa TO bar. ECN#E0047 10-23-02 S.R. H.N. AK REVISED VIEW OF TERMINAL BLOCK & SPECS. ECN#C8438 11-22-99 S.R. VPD AJ CERTIFICATION WAS CSA. REQUIREMENT NOTE WAS NEMA 4X, 7, 9. ECN#C7775 12-3-98 P.V. S.F. AH REDRAWN, ADDED 1" (25.4mm) & 5/16 (7.94mm) DIMENSIONS. ECN#C684B 10-31-97 P.W. A.M.					DWG NO A-12756			
SYMBOL DESCRIPTION DATE DWN APPD					SCALE HALF			
REVISIONS					DO NOT SCALE THIS DRAWING			