



Certificate of Compliance

Certificate: 70212106 **Master Contract:** 164460 (065182_0_000)
Project: 70212106 **Date Issued:** 2019-03-29
Issued to: **Appleton Group Ltd.**
 9377 W Higgins Rd
 Rosemont, Illinois 60018
 USA
 Attention: Steve Blais

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: *Steven Simkevitz*
 Steven Simkevitz

PRODUCTS

CLASS - C342883 - FIXTURES AND FITTINGS-For Hazardous Locations-Certified to U.S. Standards
CLASS - C342803 - FIXTURES AND FITTINGS-For Hazardous Locations

Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G; Class III; T-coded per table below; Type 3R, 4, 4X; IP66; Marine Outside Type (Salt Water) for USA only;

Rigmaster Linear LED luminaires for use in hazardous locations; ceiling surface or wall surface mounted; rated input voltage 120-277 VAC 50/60 Hz, 125-300 VDC or 347-480 VAC 50/60 Hz, 60 Watts max; T_{ambient} -40 °C to +65 °C per table below.

Catalogue number RM may be followed by A, B, L or N, followed by 2 or 4, may be followed by 1, 2 or 3, followed by C, N or W, followed by D or P, followed by L, followed by BU or BH, followed by N, followed by G, followed by W or T.

Series Number	Min Supply Wire (C°)	Max Driver Current (mA)	Max Ambient Temp. (C°)	Class I Division 2 Groups A, B, C and D	Class I, Zone 2, Group IIC	Class II, Division 2, Groups F and G	Zone 22, Group IIIC	Class I, Division 2 & Class II, Division 2
RM*2***LB*NG*	90	600	40	T6	T6	T6	T6	T5
			55	T5	T5	T5	T5	T4A



Certificate: 70212106
Project: 70212106

Master Contract: 164460
Date Issued: 2019-03-29

			65	T4A	T4	T4A	T4	T4A
RM*4***LB*NG*	90	1040	40	T5	T5	T6	T6	T5
			55	T4A	T4	T5	T5	T4A
			65	T4A	T4	T5	T5	T4A

Notes:

1. *** Series model RM is followed with alphanumeric suffixes to denote electrical and mechanical variations. Refer to nomenclature for details.
2. Marine Outside Type (Salt Water) rating applies to installation in the USA only.
3. Luminaire for marine application in the US is intended to be installed in accordance with CG-259 American Bureau of Shipping and Coast Guard requirements.
4. May be additionally marked Class I, Zone 2, IIC; Zone 22;

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 0-10	-	General requirements — Canadian Electrical Code, Part II
CAN/CSA C22.2 No. 94.2-15	-	Enclosures for electrical equipment, environmental considerations
CAN/CSA C22.2 No. 137-18	-	Electric Luminaires for Use in Hazardous Locations
CAN/CSA C22.2 No. 250.0-18	-	Luminaires
CAN/CSA C22.2 No. 250.13-17	-	Light emitting diode (LED) equipment for lighting applications
CAN/CSA C22.2 No. 60529:16	-	Luminaires — Part 1: General requirements and tests
UL 50E, Second Edition	-	Enclosures for electrical equipment, environmental considerations
UL 844, Thirteenth Edition	-	Luminaires for Use in Hazardous (Classified) Locations
UL 1598, Fourth Edition	-	Luminaires
UL 8750, Second Edition	-	Light Emitting Diode (LED) Equipment for Use in Lighting Products



Supplement to Certificate of Compliance

Certificate: 70212106

Master Contract: 164460 (065182_0_000)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70212106	2019-03-29	Original Hazardous Locations Certification for North America, for the Rigmaster Linear LED Luminaire for the following ratings: Class I, Division 2, Groups A, B, C, D; Class II, Division 2, Groups F, G; Class III; Type 3R, 4, 4X; IP 66.